



**BANGALORE UNIVERSITY**  
**DEPARTMENT OF CIVIL ENGINEERING - U.V.C.E**  
Jnana Bharathi, Bengaluru - 560 056.

☎ : 080-22961155  
080-22961662

☎ : +91-9480306449  
+91-8618075825  
+91-9980825006



Date: 07.06.2023

To,  
The Assistant Executive Engineer  
Public Works Department (PWD)  
Chikkanayakanahalli Sub Division, Tumkur District.

Sir,  
Sub: Structural stability Evaluation report of Vidyavaridhi International School Dugudihalli, Chikkanayakanahalli Taluk, Tumkur District – 572226

Ref: Management letter to M/s Sreetech Supports dated 02.06.2023

With Reference to the above request made by Management we visited Vidyavaridhi International School Dugudihalli, Chikkanayakanahalli Taluk, Tumkur District – 572226 on 05.06.2023 in the presence of representatives from school management and Sreetech Supports. The details of structural stability of the building are as follows.

**INFERENCE**

Based on the present condition of the building and the test result submitted by Sreetech Supports, Bangalore it is inferred that the building comply with safety and serviceability requirements as expected as per available code of practice.

**CONCLUSIONS**

The Vidyavaridhi International School Dugudihalli, Chikkanayakanahalli Taluk, Tumkur District – 572226 is the building composed of one block Ground and three floors as roof element comply with the safety and serviceability requirements as per report attached, hence building is **advisable for any tenancy or occupancy.**

The above said building is fit, stable, safe and firm for running the School with effective from June 07, 2023 for a period of three years till June 07, 2026.

The building is safe for occupancy as per Volume – 1 of National Building Code of India-2016 guidelines.

**Note:**

- Maintain the Building with frequently by Crack Sealing works at visible hairline cracks, painting, sanitary and water flow pipes etc.*
- Newly constructed buildings are need to apply live load on floor wise by keep observing the settlement of building for certain period, Water tanks or fire water tanks shall be placed on the place for which it is designed by considering the water tank load.*
- These results are valid for the items tested at site and water table level during construction.*
- Provide basic facilities for old Aged and Handicapped personals*
- The dampness in RCC Roof, Beam and Brick Masonry Wall may be due to leak in water conduits. The dampness may deteriorate the RCC members by causing rusting in Reinforcement.*

Encl: NDT report

Thank you

Yours faithfully

*B. Kawith*  
**PRESIDENT**

**KIRANA KUMARA SEVA TRUST®**  
**GANDIPET HULIYAR-572218**

*N. Jayaramappa*  
**Dr. N. Jayaramappa**  
B.E(Civil), M.E(Structures), Ph.D.  
Professor & Chairman-BOE (Str/Psc)  
Department of Civil Engineering  
UVCE, Bangalore University,  
Bengaluru - 560 056.

*Chandrasekhar*  
**PRINCIPAL**

**VIDYAVARIDHI INTERNATIONAL SCHOOL**  
**DUGADIHALLI CHIKKANAYAKANAHALLI-572226**

Date: 07.06.2023

To,  
**The Assistant Executive Engineer**  
Public Works Department (PWD)  
Chikkanayakanahalli Sub Division, Tumkur Dist.

Sir,

**Sub:** Structural stability Evaluation report of Vidyavaridhi International School Dugudihalli, Chikkanayakanahalli Taluk, Tumkur District - 572226

With Reference to the above subject, I am hereby attaching the Structural stability report of below mentioned structure jointly executed by Sreetech Supports and Bangalore University for your Consideration and approval.

**Name and address of the Building:** Vidyavaridhi International School Dugudihalli, Chikkanayakanahalli Taluk, Tumkur District - 572226

The above said building is fit, stable, safe and firm for running the school with effective from June 07, 2023 for a period of three years till June 07, 2026.

**Note:** It is essential that the above said building should undergo necessary annual and special maintenance whenever required.

Please consider the same

Assuring Quality service all the Time

Thanking You

Regards

Enclosures:

1. Observations and Conclusion from Bangalore University
2. Structural Stability Report

For SREE TECH SUPPORTS

*T.K.L.O.*  
Authorized Signatory

*B. Kavitk*  
PRESIDENT

KIRANA KUMARA SEVA TRUST®  
GANDIPET HULIYAR-572218

*Chayudh*  
PRINCIPAL

VIDYAVARIDHI INTERNATIONAL SCHOOL  
DUGADIHALLI CHIKKANAYAKANAHALLI-572226



HO: 1<sup>st</sup> Main, 10<sup>th</sup> cross Doddabettahalli Layout, Vidyanarayapura post, Bengaluru-560097, Karnataka  
BO: #1135/25 Behind Kasturba Hospital, Someshwara Extension, SS Puram, Tumkur-572102, Karnataka

email: [services@sreetech@gmail.com](mailto:services@sreetech@gmail.com), [tmksreetech@gmail.com](mailto:tmksreetech@gmail.com)

Mobile: +91 9964677144/8277362080/ 9482516497

MSME Registration: UAN KR03D0055331, UDYAM-KR-03-0070113

